



MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT
NARELA ZONE

No. DHO/NRZ/2023/D-5/4

Dated: 28/6/23

SCHOOL HEALTH CERTIFICATE

Date of Inspection : 27.06.2023

1. Name of School : BHAGAT JI MEMORIAL MODEL (SR. SEC.) SCHOOL
2. Address : 34/8/1, Yamuna Road, Palla, Delhi-110036
3. No. of Shifts : One Timing 08:00 AM to 02:00 PM

Accommodation Provided

THE FLOOR AREA IN THE CLASSROOM IS SUFFICIENT.

THE CLASSES ARE WELL LIGHTED.

THE CLASSROOMS ARE WELL VENTILATED.

THE CLASSROOMS ARE KEPT NEAT AND CLEAN.

THE DRINKING WATER IS WATER TEST REPORT APPROVED BY DJB Lab..


THE TOILET ARRANGEMENT IS SANITARY & HYGENIC AND SUFFICIENT IN NUMBER.


Remarks :


THIS CERTIFICATE DOES NOT INDICATE PERMISSIBILITY FROM LAND POINT OF VIEW.

The certificate is valid for a period of one year from the date of issue.

The Vice Principal
BHAGAT JI MEMORIAL MODEL (SR. SEC.) SCHOOL
34/8/1, Yamuna Road, Palla, Delhi-110036



JAI PRAKASH
(Vice Principal)
Bhagat Ji Memorial Model School
(Recognised)
34/8/1, Yamuna Road, Palla, Delhi-110036


28/6/23
Dy. Health Officer
Narela Zone
Narela Zone


SUNITA KUMARI
(Manager)
Bhagatji Memorial Model (Sec.) School
(Recognised)
34/8/1, Yamuna Road, Palla, Delhi-110036



DELHI JAL BOARD: GNCTD
CENTRAL LABORATORY WTP WAZIRABAD, DELHI-54



448

07-06-23

TEST REPORT

Sample ID	Ref No DJB/CWA/Wzd/2023-24/paid-44-45		
Location /Address of Sample	Bhagat Ji Memorial Model Sr. Sec School 34/8/1 Yamuna Road Palla Delhi-36		
Reference No	F-BMMS/Palla /2023/223	Ref. Letter Date	26.05.2023
Challan No	90	Challan Date	30.05.2023
Sample Collection date	03.06.2023	Analysis date	03.06.2023
Any other Information	--	Reporting date	06.06.2023

TEST RESULTS

S.No.	Parameters	Unit	As per the IS 10500		Inlet	Outlet
			Desirable limit	Permissible limit		
1	Turbidity	NTU	1	5	1.8	1.0
2	pH Value		6.5-8.5	No relaxation	7.62	7.27
3	Colour	Pt-Co	5	15	2.0	1.0
4	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
5	Electrical Conductivity	µS/cm			974	102
6	Total Dissolved Solids	mg/L	500	2000	633	66
7	Total Alkalinity as CaCO ₃	mg/L	200	600	164	26
8	Total Hardness as CaCO ₃	mg/L	200	600	240	18
9	Calcium as Ca	mg/L	75	200	67	05
10	Magnesium as Mg	mg/L	30	100	17	1.4
11	Ammonical-Nitrogen	mg/L	NIL	0.5	BDL	BDL
12	Nitrate	mg/L		45	3.8	1.3
13	Chlorides as Cl	mg/L	250	1000	188	10
14	Fluoride as F	mg/L	1.0	1.5	0.47	0.12
15	Sulphate as SO ₄	mg/L	200	400	58.9	1.6
16	Total Iron	mg/L		1.0	0.10	0.04
17	Residual Chlorine	mg/L	0.2	1.0	0.50	BDL
18	COLIFORM COUNT AT 37 °C	MPN/100 mL	Absent		0	0

End of Report

Remarks: For the tested parameters water sample confirm IS-10500 & is fit for drinking purpose.

Jayshree
Tested by
Lab. Tech.

Dabare
Verified by
Asstt. Chemist

Sunita
Authorized by
Chemist/ACWA

Jai Prakash
JAI PRAKASH
(Vice Principal)
Bhagat Ji Memorial Model School
(Recognised)
34/8/1, Yamuna Road, Palla, Delhi-110036

Sunita
SUNITA KUMARI
(Manager)
Bhagatji Memorial Model (Sec.) School
(Recognised)
34/8/1, Yamuna Road, Palla, Delhi-110036